

5186 Stump Road
PO Box 387
Plumsteadville, PA 18949



Phone (215) 766-8914
Fax (215) 766-9831

ACTIVE PUBLIC WELL TESTING RESULTS

CABIN RUN WELL # 2

Perfluorooctanoic acid 2 PPT (J)
Perfluorononanoic acid 1 PPT (J)

CABIN RUN WELL #3

Perfluorooctanoic acid 7 PPT
Perfluorononanoic acid 2 PPT (J)
Perfluorotetradecanoic acid 3 PPT (J)
Perfluorohexanoic acid 7 PPT
Perfluoroheptanoic acid 2 PPT
Perfluorbutanesulfonate 5 PPT (J)
Perfluoro-octanesulfonate 9 PPT (J)

COUNTRY GREEN WELL #1

Perfluorooctanoic acid 4 PPT
Perfluorononanoic acid 2 PPT (J)
Perfluorohexanoic acid 3 PPT
Perfluoroheptanoic acid 2 PPT (J)

COUNTRY GREEN WELL #2

Perfluorooctanoic acid 4 PPT
Perfluorononanoic acid 1 PPT (J)

DURHAM RIDGE WELL #1

Perfluorooctanoic acid 5 PPT
Perfluorononanoic acid 1 PPT (J)

LANDIS GREENE WELL #6

Perfluorohexanesulfate acid 10 PPT (J)

NORTH BRANCH WELL #2

Perfluorooctanoic acid 1 PPT (J)

NORTH BRANCH WELL #3

Perfluorooctanoic acid	3 PPT
Perfluorohexanoic acid	2 PPT (J)
Perfluoroheptanoic acid	1 PPT (J)

SUMMER HILL WELL #6

Perfluorooctanoic acid	5 PPT
Perfluorononanoic acid	1 PPT (J)
Perfluorohexanoic acid	1 PPT (J)
Perfluorohexanesulfonate	7 PPT (J)
Perfluoro-octanesulfonate	7 PPT (J)

SUMMER HILL WELL #7

Perfluorooctanoic acid	8 PPT
Perfluorononanoic acid	2 PPT (J)
Perfluorohexanoic acid	4 PPT
Perfluoroheptanoic acid	4 PPT
Perfluorbutanesulfonate	8 PPT (J)
Perfluorohexanesulfonate	7 PPT (J)
Perfluoro-octanesulfonate	8 PPT (J)

The EPA has revised its health advisory for PFCs to 70 parts per trillion.

(J) Indicates an estimated value. This flag is used when the mass spectral data indicate the presence of an analyte meeting all the identification criteria, but the result is less than the Contract Required Quantitation Limit (CRQL), but greater than zero. (source: EPA Contract Laboratory Program)

Samples Collected: 06/23/2016