



## 2020 ANNUAL DRINKING WATER QUALITY REPORT

### PWSID #: 1090157 - Plumstead Township Summer Hill Water System

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.* (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

#### WATER SYSTEM INFORMATION:

This report defines our water quality, services, and briefly describes testing information and results. The Summer Hill Water System serves Plumstead residents in the Summer Hill and Summer Meadow developments. If you have any questions concerning this report or your water utility, please contact Alan Bleam, Director of Public Works for Plumstead Township at 215-766-0189.

We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled Board of Supervisors meetings. The meetings are generally held the second and fourth Tuesday of the month beginning at 7:30 PM at the Plumstead Township Municipal Building, 5186 Stump Road, Pipersville, PA 18947. Please check the township website at [www.plumstead.org](http://www.plumstead.org) or call 215-766-8914 to confirm dates and times of the meetings to be held.

#### SOURCE(S) OF WATER:

The public water supply serving your system relies on groundwater sources located in the Summer Hill and Summer Meadow developments. The wells are known as SH-5, SH-6, and SH-7. We are pleased to inform you that your water meets or exceeds all USEPA and PA DEP drinking water standards. The standards set forth in the Safe Drinking Water Act uphold very stringent quality testing levels with regard to health effects. To understand the possible health effects described by many regulated constituents, a person would have to drink two liters of water every day at the Maximum Contaminant Level (MCL) for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* at 1-800-426-4791.

#### MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2020. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

## DEFINITIONS:

*Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Minimum Residual Disinfectant Level (MinRDL)* - The minimum level of residual disinfectant required at the entry point to the distribution system.

*Level 1 Assessment* – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

*Level 2 Assessment* – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

*Treatment Technique (TT)* - A required process intended to reduce the level of a contaminant in drinking water.

*Mrem/year* = millirems per year (a measure of radiation absorbed by the body)

*pCi/L* = picocuries per liter (a measure of radioactivity)

*ppb* = parts per billion, or micrograms per liter ( $\mu\text{g/L}$ )

*ppm* = parts per million, or milligrams per liter (mg/L)

*ppq* = parts per quadrillion, or picograms per liter

*ppt* = parts per trillion, or nanograms per liter

**DETECTED SAMPLE RESULTS:**

<b>Chemical Contaminants</b>								
<b>Contaminant</b>	<b>MCL in CCR Units</b>	<b>MCLG</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Chlorine	MRDL = 4	MRDL = 4	1.83	1.16 - 1.83	ppm	2020	N	Water additive used to control microbes.
Haloacetic Acid (HAA5)	60	N/A	1.2	N/A	ppb	2020	N	By-product of drinking water chlorination
Nitrate	10	10	1.43	N/A	ppm	2020	N	Runoff from fertilizer use, leaching from septic tanks, sewage, erosion from natural deposits
Trihalomethanes (TTHMs)	80	N/A	27	N/A	ppb	2020	N	By-product of drinking water chlorination
Sulfate	N/A	N/A	47	N/A	mg/l	2019	N	Dissolved minerals, namely sodium sulfate (saltcake), magnesium sulfate (Epsom salts) and calcium sulfate (gypsum). Can also come from fertilizer or sewage treatment.
Combined Uranium	30	0	9.27	1.18 - 9.27	ppb	2019	N	Erosion of natural deposits
Gross Alpha	15	0	17.6	0.0 - 17.6	pCi/L	2019	Y	Erosion of natural deposits
Radium 226	5	0	1.32	0.37 - 1.32	pCi/L	2019	N	Erosion of natural deposits
Radium 228	5	0	0.63	0.00 - 0.63	pCi/L	2020	N	Erosion of natural deposits

\*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health. Plumstead Township does not add **Fluoride** to the source water.

\*Arsenic results have a running annual average for the calculation of sample results.

<b>Entry Point Disinfectant Residual</b>							
<b>Contaminant</b>	<b>Minimum Disinfectant Residual</b>	<b>Lowest Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Chlorine EP 102	0.45	0.00	0.00 - 2.90	mg/l	04/17/2020	N	Water additive used to control microbes
Chlorine EP 103	0.40	0.00	0.00 - 2.73	mg/l	01/04/2020	M	Water additive used to control microbes

<b>Lead and Copper</b>							
<b>Contaminant</b>	<b>Action Level (AL)</b>	<b>MCLG</b>	<b>90<sup>th</sup> Percentile Value</b>	<b>Units</b>	<b># of Sites Above AL of Total Sites</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Lead (2019)	15	0	0	ppb	0 of 20	N	Corrosion of household plumbing
Copper (2019)	1.3	1.3	0.397	ppm	0 of 20	N	Corrosion of household plumbing

<b>Microbial (related to E. coli)</b>					
<b>Contaminants</b>	<b>MCL</b>	<b>MCLG</b>	<b>Positive Sample(s)</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
<i>E. coli</i>	Routine and repeat samples are total coliform-positive <b>and</b> either is <i>E. coli</i> -positive <b>or</b> system fails to take repeat samples following <i>E. coli</i> -positive routine sample <b>or</b> system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> .	0	0	N	Human and animal fecal waste

<b>Raw Source Water Microbial</b>					
<b>Contaminants</b>	<b>MCLG</b>	<b>Total # of Positive Samples</b>	<b>Dates</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
<i>E. coli</i>	0	0	N/A	N	Human and animal fecal waste

**OTHER VIOLATIONS:**

Compliance reports for volatile organic compounds were sampled for the 2<sup>nd</sup> quarter of 2019, but were not submitted to the regulatory agency by the prescribed time. All sample results were below Safe Drinking Water Act standards.

**EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791. You may also visit the EPA groundwater website at [www.epa.gov/groundwater-and-drinking-water](http://www.epa.gov/groundwater-and-drinking-water).

#### **INFORMATION ABOUT LEAD:**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our contracted State Licensed Water Works Operator is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the *Safe Drinking Water Hotline* or at <http://www.epa.gov/safewater/lead>.

#### **OTHER INFORMATION:**

Plumstead Township continually works to provide top quality water to every customer on the system every day. Please help protect this precious resource by disposing of waste properly and conserving usage at all times. Protecting our water resources, which are at the heart of our community, our way of life, and our children's future, is a good thing to do!

In order to maintain a dependable and safe water supply, we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments.

Thank you for your cooperation.